GSTIN 19BAPPS0902R1ZW Call/Text/Watsapp 24x7:-8327718656

ERTIF

MPA



"KABSON" Fire Fighter is the most adorable Fire Suppression & Protection Brand.

We are an ISO Certified ISO 9001:2015 pioneer in Fire & Safety Equipment's. Concurrently we are a certified organization for NSIC under Ministry of Small & Medium Enterprise (MSME), Government of India & simultaneously licensed under Udyam Adhar under ministry of Micro, Small & Medium Enterprise, Government of India

We have specialization in Fire Detection, Suppression & Protection; we also provide Certified Fire Training & are master in handling Turnkey Project's in Fire Detection, Suppression & Evacuation.

The Unique features of "KABSON" Fire Extinguishers are





GSTIN 19BAPPS0902R1ZW

Call/Text/Watsapp 24x7:-

8327718656



*Terms & Condition Applicable as per policy

UNIT	SPECIFICATION*	
"KABSON" CLEAN AGENT -4KG	Extinguishing Agent	Clean Agent 'UL Listed'
<image/>	Details	4Kg
	Gross Weight	6.9 Кg
	Empty Weight	2.9 Kg
	Can Height	440MM
	Diameter	140MM
	Sheet metal thickness	1.60MM
	Pressuring Agent	Nitrogen Pressurized (Inert Gas)
	Pressure Monitor	CE Approved Pressure Gauge
	Discharge	Controllable Discharge Mechanism
		Discharge Hose & Nozzle
	Discharge time	Minimum 8 Secs
	Range	Minimum 2 Meters
	Operating Temperature	(-)200C to (+)550C
	Can Construction	Deep Drawn & CO2 Mig welded
	Valve Construction	Forging & Machining



GST

TIN 198APPS0902R1ZW Text/Watsapp 24x7:- 3327718656		
<image/>	Internal Coating of Can	Epoxy Powder coating KABSON F WWW.KABSONFIRE
	External Coating of Can	Epoxy Polyester Powder coating
	Test	In house test as per IS- 15683:2018**
	Applicable on	Class A,B, C and electrically started Fire
	A Rating	1 A
	B Rating	21B Make & Construction: - As per IS-
	Certifications	15683:2018 Maintenance & Schedule: - As Per IS 2190:2010
		CE Approved
	Warranty	3 Years***
	Extended Warranty	3 Years****
	Shell Life Warranty	10 Years****

* Technical specifications are subject to change with time due to our continuous product improvisation initiatives.

** In house test as per IS-15683:2018(annx C) compliance & policy (Kindly Visit our website or BIS website for details rules & regulation)

***Warranty As per IS-2190:2010(annex D clauses 11.4.1 & 12.3) compliance & policy (Kindly Visit our website or BIS website for details rules & regulation).



GSTIN 19BAPPS0902R1ZW

Call/Text/Watsapp 24x7:-8327718656

*****It is mandatory for the extinguisher to be refilled/ replaced by "KABSON" in the 3rd year as per IS-2190:2010(annex E clauses 12.2.1 & 12.2.2g) compliance & policy (Kindly Visit our website or BIS website for BS on FIRE details rules & regulation)

***** Shell Life Warranty as per IS-2190:2010(annx F clauses 12.2.1) compliance & policy (Kindly Visit our website or BIS website for details rules & regulation)

(Kindly Visit our website or BIS website for details compliance & parameters)

