#### GSTIN 19BAPPS0902R1ZW

#### Call/Text/Watsapp 24x7:-8327718656



"KABSON" Fire Fighter is the most adorable Fire Suppression & Protection Brand.

We are an ISO Certified ISO 9001:2015 pioneer in Fire & Safety Equipment's. Concurrently we are a certified organization for NSIC under Ministry of Small & Medium Enterprise (MSME), Government of India & simultaneously licensed under Udyam Adhar under ministry of Micro, Small & Medium **Enterprise, Government of India** 

We have specialization in Fire Detection, Suppression & Protection; we also provide Certified Fire Training & are master in handling Turnkey Project's in Fire Detection, Suppression & Evacuation.

### The Unique features of "KABSON" Fire Extinguishers are



- **Elegant Look.**
- Agronomical Design.
- Seamless Cylindrical Body.
- World Class Valve Assembly.
- **Best Quality Rubber Hose Pipes**
- Time Tested & rigorous in House Test Qualified as Per Prescribed Norms.
- Compliance to Statuary Norms of BIS Norms & CE
- **Unique Warranty Policy\***
- Shell Life Warranty As Per IS-15683:2018 & IS 2190:2010
- Extended Warranty\*
- Complimentary AMC\*
- Introduction of ACMC\*
  - Sanitized Installation Process & Maintenance.
- Sanitized Gloves with every Unit
- **Installation Strictly As per Risk Assessment Team**

Images may differ from actual product

# SHIPRA VENTURE

BD-24, THAKUR RAMAKRISHNA SARANI, PRAFULLA KANON, KESTOPUR, KOLKATA-700101 LANDLINE: 033-35642706, MOBILE: 7980949473 / 9474945560

> SALES@SHIPRAVENTUR.IN / INFO@KABSONFIRE.COM WWW.SHIPRAVENTURE.COM / WWW.KABSONFIRE.COM

European Agency for Safety and Health









### 8327718656

### \*Terms & Condition Applicable as per policy



WWW.RABSONFIRE.COM		
UNIT	SPECIFICATION*	
KABSON WET CHEMICAL-6 LTRS	KABSON Brand Wet Chemical (Stored Pressure Type)	
KABSONG FRE FIGHTER  WETCHEMICAL  REPORTS THE GRANGE  WETCHEMICAL  REPORTS THE GRANGE  REPORTS THE GRANGE	Extinguishing Agent	Wet Chemical (Potassium Based)
	Details	9Ltr
	Gross Weight	16.9 kg
	Empty Weight	5.05 kg
	Can Height	610 mm
	Diameter	175 mm
	Discharge time	Minimum 15 Secs
		Controllable Discharge
		Mechanism,
	Discharge Mechanism	Discharge Hose & Nozzle
	Range	Minimum 2 Meters
	Pressuring Agent	Nitrogen Pressurized (Inert Gas)
	Pressure Monitor	CE Approved Pressure Gauge
		Burst Pressure55/80 bar min., 110 bar (actual) approx
		( ( <b> / P.F.</b> 0
	Pressure	Cylinder Testing Pressure35 bar for 30 sec.
		Operating Pressure12 bar Min.





at Work

# SHIPRA VENTURE

BD-24, THAKUR RAMAKRISHNA SARANI, PRAFULLA KANON, KESTOPUR, KOLKATA-700101 LANDLINE: 033-35642706, MOBILE: 7980949473 / 9474945560

SALES@SHIPRAVENTUR.IN / INFO@KABSONFIRE.COM WWW.SHIPRAVENTURE.COM / WWW.KABSONFIRE.COM







#### GSTIN 19BAPPS0902R1ZW

Images may differ from actual product

Working Temperature	°C+5°C to +60°C	
Applicable on	Class-A, Class-B, Class-F and Electrically Started Fires	
F Rating	75	
A Rating	8	
Test	In house test as per IS- 15683:2018**	
Sheet metal thickness	1.50MM	
Certification Standard	Make & Construction: - As per IS-15683:2018	
	Maintenance & Schedule: - As Per IS 2190:2010	
	CE Approved	
Warranty	3 Years***	
Extended Warranty	3 Years***	
Shell Life Warranty	10 Years****	

\*\*\*\*\*It is mandatory for the extinguisher to be refilled/ replaced by "KABSON" in the 3rd year as per IS-2190:2010(annex E clauses 12.2.1 & 12.2.2g) compliance & policy (Kindly Visit our website or BIS website for details rules & reaulation)

\*\*\*\*\* Shell Life Warranty as per IS-2190:2010(annx F clauses 12.2.1) compliance & policy (Kindly Visit our website or BIS website for details rules & regulation)

(Kindly Visit our website or BIS website for details compliance & parameters)



## SHIPRA VENTURE

BD-24, THAKUR RAMAKRISHNA SARANI, PRAFULLA KANON, KESTOPUR, KOLKATA-700101

LANDLINE: 033-35642706, MOBILE: 7980949473 / 9474945560

SALES@SHIPRAVENTUR.IN / INFO@KABSONFIRE.COM WWW.SHIPRAVENTURE.COM / WWW.KABSONFIRE.COM











<sup>\*</sup> Technical specifications are subject to change with time due to our continuous product improvisation initiatives.

<sup>\*\*</sup> In house test as per IS-15683:2018(annx C) compliance & policy (Kindly Visit our website or BIS website for details rules & regulation)

<sup>\*\*\*</sup>Warranty As per IS-2190:2010(annex D clauses 11.4.1 & 12.3) compliance & policy (Kindly Visit our website or BIS website for details rules & regulation).